


KEY TO DIAGRAM	
A1	- DUNGS MPA CONTROL
F1	- THERMAL RELAY
H1	- OPERATION LAMP
H2	- LOCKOUT LAMP
K1	- MOTOR CONTACTOR
MV	- MOTOR
S1	- ON-OFF SWITCH
S4	- AUTO-MAN SWITCH
S5	- MIN-MAX SWITCH
S24	- START-STOP SWITCH
TA	- IGNITION TRANSFORMER
TC	- CONTROL STAT
TS	- SAFETY STAT
X1.	- BURNER TERMINAL RAIL
YP	- MAIN GAS VALVE
YS	- SAFETY GAS VALVE
X2	- 7-POLE CONNECTOR
X3	- 4-POLE CONNECTOR
RWF40	- MODULATING CONTROLLER
Pt	- TEMPERATURE SENSOR
PM	- MAX GAS ORESSURE SWITCH
H3	- REMOTE LOCKOUT LAMP
H4	- REMOTE OPERATION LAMP



KEY TO DIAGRAM	
A1	- DUNGS MPA CONTROL
Pm	- MIN GAS PRESSURE SWITCH
PA	- AIR PRESSURE SWITCH
B1	- IONIZATION PROBE
GAS Y8	- GAS SERVO MOTOR
AIR Y10	- AIR SERVO MOTOR

