



Reliable energy. Flexible approach.

EOGB Energy Products Ltd
5 Howard Road, Eaton Socon,
St. Neots, Cambs. PE19 8ET
T: 01480 477066 **F:** 01480 477022
Email: sales@eogb.co.uk
Web site: www.eogb.co.uk
Co Reg: 1951401 **VAT No:** 573 3493 23

General Flexible Oil Hose Statement

Latest issue 01-08-21

These hoses have been designed to provide a safe flexible connection between the burner and the incoming oil supply on oil burner installations. EOGB Ruby Red and EOGB Bio Green flexible hoses are tested and suitable for Kerosene and Gas oil liquid fuels conforming to BS 2869:2017 and biofuels blends including FAME and HVO to 100%

Please note: If the hose is used for other non-heating oil applications, then the warranty is void including Non-standard oil applications

Ruby Red Flexibles

These hoses have a 5-year Manufacturers warranty and a 10 year end of life from the date stamped on the crimp and is tested in accordance with ISO-6806
The hose must not be kinked or stretched.

Green Bio Flexibles

These hoses now have a 3-year Warranty (as of 1st April 2019, 2 years prior to this date).
from the date stamped on the crimp
The hose must not be kinked or stretched.

Steel Braided Flexibles

EOGB no longer provide braided flexible oil lines.

Black High-Pressure Flexibles

These hoses have a 1-year warranty from the date stamped on the crimp.
(Please note that these flexibles have not been tested with bio fuel blends and are only suitable for Kerosene and Gas oil to BS 2869)
The hose must not be kinked or stretched.

Recommendations

We recommend that the hoses are replaced if there are any signs of cracking, kinking or abrasions. If in any doubt regarding the age of the hose, then it should be immediately replaced.

All hoses have been manufactured from high quality materials, but like all rubber and plastic materials they do eventually change their characteristics due to varying environmental, operating and site conditions.

It is impossible to establish the internal condition of the hose to decipher if any degradation has taken place. It is highly recommended to adhere to Oftec guidelines where it is stipulated that hoses are changed during the annual service and/or no more than 1 year after the warranty expiry date which is stamped clearly on the hose crimp